



IBI GROUP
3rd Floor – 227-11 Avenue SW
Calgary AB T2R 1R9 Canada
tel 403 270 5600 fax 403 270 5610
ibigroup.com

January 26, 2021

Mr. Paul Saik, CET
Sr. Civil Engineering Technologist
Development & Infrastructure Services
City of Chestermere
105 Marina Road
Chestermere, AB T1X 1V7

Dear Mr. Saik:

**CLEARWATER PARK
TECHNICAL MEMORANDUM SANITARY SERVICING - REVISED**

Further to your comments on our December 24th, 2020 sanitary servicing technical memorandum, we submit the attached revised sanitary servicing technical memorandum for your consideration and approval.

These comments and our responses are summarized below:

1. Page 3 – Please change Option 1 wording - “This option is no longer being considered.”
Response: The wording has been updated as advised.
2. Page 3 - Option 2 is worded incorrect – “East Chestermere gravity trunk is to drain to LS #14.”
Response: This has been updated as advised.
3. The sanitary generation rate can be updated to 250L/c/day.
Response: The generation rate has been updated to 250L/c/day.

We trust this information is sufficient for your review. Should you have any questions, please do not hesitate to contact the undersigned at (403) 270-5600.

Yours truly,

IBI GROUP

A handwritten signature in blue ink that reads "Michael Slattery".

Michael Slattery, P. Eng.
Project Engineer

cc: Centron Group, David Dalen
Vicinia Planning & Engagement Inc., Liz Armitage
IBI Group, Rod Sieker, Elvin Karpovich, Harry Shnider
File No. 121935.6.2.3

J:\121935_BayfieldLndsl6.0_Technical\6.2_Civil_Eng_Muni_Transpl6.2.3_Tech-Reports\Sanitary Servicing Study\Jan 2021 Submission\CTLSaik_121935_SanitaryServicingMemo_Letter_2021-01-26.doc